

MARCH 2015 FLOOD  
EVENT (17.52M AOD)

KEMP PROPOSED STOP GENERATING  
TBC (SEE NOTE 1)

LEVEL EXCEEDED 1%  
OF TIME (16.38M AOD)

LEVEL EXCEEDED 50%  
OF TIME (15.82M AOD)

LEVEL EXCEEDED 99%  
OF TIME (15.45M AOD)

KEMP HANDS OFF LEVEL DUE TO  
EXISTING PSH AND ENVIRONMENTAL  
(TBC) (SEE NOTE 1)

CALEDONIAN CANAL  
MINIMUM OPERATING  
LEVEL (15.27m AOD)

18

17

16

15

14



Notes

1. EXACT KEMP CURTAILMENT LEVEL TO BE AGREED WITH SEPA AND OTHER RELEVANT STAKEHOLDERS.

Loch Kemp Storage  
EIA Report

Figure 7.3  
Historic Loch Ness Levels with Pumped  
Hydro Curtailment Levels

Drawn by: DW Date: 31/10/2023

Drawing: S3864-8300-0003DW R5.0



Loch Kemp  
Storage  
A STATERA COMPANY



FICHTNER  
CONSULTING ENGINEERS LIMITED